

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. T 9249

Dated 11/09/2026

It is certified that an inspection team headed by

Mudassir Clerk

(Name of Officers with designation)

from District Level Water Analysis Lab, UP Jal Nigam (Rural) BSR PHED

inspected the Chandrawati Public School, Bugrasi Road, Siyana

(Name & Address of the school) on 04/09/2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. T 9249

dated 11.09.2026 for 03.09.2027 (PHED Lab)

certified that the Chandrawati Public School Bugrasi, Road Siyana (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 03/09/2027

Signature with Seal

Name

Designation

Name & Address of the Office / Department

To Chandrawati Public School Bugrasi Road Siyana
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Analysis Laboratory
UP Jal Nigam (Rural), Bulandshahr

TEST REPORT

UTR NO:	:	T 9249	Issue Date	11/09/2026
Sample receipt Date:	:	03/09/2026	Expired Date	03/09/2027
Customer/Party Name	:	CHANDRAWATI PUBLIC SCHOOL BUGRASI ROAD SIYANA		
Address	:	NAGAR PALIKA PARISHAD SIYANA		
Contact No.	:	8859600549		
Date of Sampling	:	04/09/2026	Sample Code:	B 75
Sample Description	:	06/09/2026	Quantity of Sample	1000ML
Quantity	:	1	Water Source	MINI NALKOOP
Packing details	:		Sampling Method	As per IS 17614:Part-2021
Analysis Start	:	09/09/2026	Analysis Completion Date	10/09/2026
Temperature	:	26.1°C	Humidity	54%
Water Sample Provided ByV.P. SINGH				
Availability of Equipments:		Availability of reference standards:	Adequacy of sample quantity	01
Availability of Test method:	IS 3025	Availability of Trained person:	Duration of testing/Time of Report release	10:30 am

TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.471	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	3.617	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	314	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	250	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	480	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	364	(Mg/L)*
7	Colour	APHA 23 rd Edistion	5	15	10	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part) : 2018	Agreeable	Agreeable	Agreeable	Agreeable
10	Calcium as Ca	-	75	200	140	(Mg/L)
11	Magnesium as	-	30	100	80.16	(Mg/L)
Remark		"The Information regarding sample collected, submitted and Customer basic details provided by the customer itself."				

Reviewed By

End of Report



Scanned with
TapScanner